

TECHNICAL DOCUMENTATION
-------------------------

TECHNICAL DOCUMENTATION & PRODUCT INFORMATION
---

PRODUCT MODEL	LGH-50RSDC-E1
---------------	---------------

Requirements	Information	
(1) Overall efficiency (%)	34.3	
(2) Measurement category	B	
(3) Efficiency category	total	
(4) Efficiency grade(N)	49	
(5) VSD	The VSD is integrated within the fan	
(6) Year of manufacture	2012	
(7) Manufacturer	<p>                     MITSUBISHI ELECTRIC CORPORATION                      HEAD OFFICE: TOKYO BUILDING 2-7-3, MARUNOUCHI, CHIYODAKU, TOKYO 100-8310, JAPAN                      AUTHORIZED REPRESENTATIVE IN EU:                      MITSUBISHI ELECTRIC EUROPE B.V.                      HARMAN HOUSE, 1GEORGE STREET, UXBRIDGE, MIDDLESEX UB8 1QQ, U.K.                      COMMERCIAL REGISTRATION NO.33279602                 </p>	
(8) Model number	LGH-50RSDC-E1	
(9)	Motor power input (kW)	0.05
	Flow rate (m <sup>3</sup> /s)	0.11
	Pressure (Pa)	144
(10) Rotations per minute	1015	
(11) Specific ratio	1.0	
(12) Information relevant for facilitating disassembly, recycling or disposal at end-of-life	<p>Your product should be disposed of separately from household waste in line with local laws and regulations.</p> <p>When this product reaches its end of life, dispose of it at your local waste collection point/recycling centre.</p> <p>The separate collection and recycling of your product at the time of disposal will help conserve natural resources and ensure that it is recycled in a manner that protects human health and the environment.</p> <p>For more information for WEEE recyclers please contact us at <a href="http://www.mitsubishielectric.eu/contact_us_form">http://www.mitsubishielectric.eu/contact_us_form</a></p>	
(13) Information relevant to minimise impact on the environment and ensure optimal life expectancy as regards installation, use and maintenance of the fan	<p>Remove all dust and dirt on air filters and 'Lossnay core's at regular intervals in order to prevent a deterioration of the fan function.</p> <p>Do not carry out the following types of duct construction.</p> <ul style="list-style-type: none"> <li>• Bends right next to the outlet</li> <li>• Extreme reduction in the diameter of the connected ducts</li> </ul>	
(14) Description of additional items used when determining the fan energy efficiency	The optimistic fan efficiency is measured in the composition of fan, motor and fan casing only.	