


**Required information for RVU in
COMMISSION REGULATION (EU) No. 1254/2014 ANNEX IV**

(a)	Supplier's name	MITSUBISHI ELECTRIC
(b)	Model name	LGH-15RVX3-E
(c)	SEC (kWh/(m2.a))	Cold: -75.6 Average: -39.2 Warm: -15.7
(d)	Declared typology	RVU,BVU
(e)	Type of drive	Multi-speed
(f)	Type of HRS	Recuperative
(g)	Thermal efficiency (%) ISO16494-1:2022	74.5
(h)	Maximum flow rate (m3/h) EN13141-7:2021	165
(i)	Electric power input (W) EN13141-7:2021	29
(j)	Casing sound power level (dB) ISO3744:2010	42
(k)	Reference flow rate (m3/s) EN13141-7:2021	0.032
(l)	Reference pressure difference (Pa) EN13141-7:2021	Supply: 65 Exhaust: 55
(m)	SPI (W/(m3/h))	0.25
(n)	Control factor and typology	Local demand control
(o)	Maximum leakage rate (%) ISO16494-1:2022 EN13141-7:2021	Internal & external: 9.7 External: 4.8
(p)	Mixing rate of non-ducted	-
(q)	Visual filter warning	Filter maintenance sign is displayed on the dedicated remote controller. Refer to the Maintenance section in the instruction manual.
(r)	Instructions to install regulated supply/exhaust grilles for unidirectional ventilation	-
(s)	Internet address for disassembly instructions	http://erp.mitsubishielectric.eu/
(t)	Airflow sensitivity for non-ducted units	-
(u)	air tightness for non-ducted units	-
(v)	AEC (kWh/a)	Cold: 7.46 Average: 2.09 Warm: 1.64
(w)	AHS (kWh primary energy/a)	Cold: 85.5 Average: 43.7 Warm: 19.8

MITSUBISHI ELECTRIC CORPORATION

Manufactured by: MITSUBISHI ELECTRIC CORPORATION

TOKYO BLDG., 2-7-3, MARUNOUCHI, CHIYODA-KU, TOKYO 100-8310, JAPAN

 **ENERG** Y UJ
енергия · ενεργεια IE IA

MITSUBISHI ELECTRIC LGH-15RVX3-E

A+
A
B
C
D
E
F
G

A

42
dB

165 m³/h

ENERGIA · ЕНЕРГИЯ · ΕΝΕΡΓΕΙΑ · ENERGIJA · ENERGY · ENERGIE · ENERGI
2016 1254/2014